

GOVERNMENT OF ANDHRA PRADESH
ROADS AND BUILDINGS DEPARTMENT

From:

N. Krishna Naik,
Executive Engineer,
(R&B) Division, Vijayawada

To

Atkinson High School
Gollapudi-521225,
Krishna District

Letter No. 1538/ECII/LC/VJA/2021 Date: 13.09.2021

Sir,

Sub:-(R&B) Division, Vijayawada – Soundness Certificate for Atkinson High School, Gollapudi,
Krishna District- Soundness of School Building certificate – Issued – Reg

Ref:- 1.) Representation of the Atkinson High School, Gollapudi, Krishna District

2.) T.O. Endt No.1538/EC-II/LC/2021, Dt.16-08-2021


3.) Lr No. Soundness Certificate/ DEE/BDS/VJA/2021 Dt.07-09-2021 of the Deputy
Executive Engineer (R&B) Building Sub-Division, Vijayawada


#

It is to inform that the Deputy Executive Engineer (R&B) Building Sub-Division, Vijayawada
has inspected to Atkinson High School, Gollapudi, Krishna District on 07-09-2022 and submitted
Soundness Certificate of School building for the period from 07-09-2021 to 06-09-2022 (One
year) and same is here with enclosed.

Encl: Soundness Certificates.

Yours faithfully


Executive Engineer (R&B)
Division, Vijayawada


13/9/2021

SOUNDNESS CERTIFICATE

| | | | |
|----|---|---|---|
| 1 | Address of the School/ College | : | Atkinson High school, D.No: 21-138, Gollapudi, Krishna(Dt). |
| 2 | College/ School Running in | : | RCC Building |
| 3 | No. of Floors | : | G+3 |
| 4 | Silt Floor/ground floor used as | : | Parking |
| 5 | constructed in the year | : | 2000 |
| 6 | constructed As per approved plan | : | Yes, Plan enclosed |
| 7 | Present period up to which certificate is in force | : | NA |
| 8 | Any cracks developed in the walls in superstructure and basement. | : | Nil |
| 9 | Condition of lintels and walls above the lintel. | : | Good |
| 10 | Condition of beams and the Trusses | : | Good |
| 11 | Development of Cracks | : | Nil |
| 12 | Exposed reinforcement if any | : | Nil |
| 13 | Condition of Doors and Windows | : | Good |
| 14 | The width of the staircase flight is | : | 1.55m against required min width of 1.50m |
| 15 | Tread width is | : | 0.30m against required width of 0.30m |
| 16 | The height of rise | : | 0.15m against required height of 0.15m |
| 17 | The height of railing | : | 0.90 m against required minimum of 1.20m |
| 18 | The height of Corridor parapet wall | : | 1.38m |
| 19 | Doorway dimensions | : | Width is 1.21m against required minimum of 1.00m & 2.08m height against 2.00m |
| 20 | Height of Parapet wall | : | 1.10 m |
| 21 | Internal corridor width | : | NA |
| 22 | Any Cantilever corridors | : | 1.52m |
| 23 | Number of exits | : | 2 Nos |
| 24 | There is high tension electricity lines passing near to the building | : | No |
| 25 | There is Petrol/Gas stations near to the building | : | No |
| 26 | Grills are provided for all sides of balconies as children safety point of view | : | To be provided in full height |

| | | | |
|---|---|---|--------------------|
| 27 | Building plan submitted | : | Yes, Plan enclosed |
| 28 | Building Foundation and Structural design submitted | : | No |
| 29 | Building was last painted in the year | : | 2019 |
| The management is advised to attend the short falls identified in the above items and submit the details in this office, Otherwise soundness Certificate will not be renewed by the department. | | | |
| How ever for the building is safe for a period of One Year i.e., from 07.09.2021 to 06.09.2022. | | | |

D.M. Prasad 07/09/21
Assistant Executive Engineer, (R&B)
Buildings, Section-V, Vijayawada.

y. s. s. 07/09/21
Deputy Executive Engineer, (R&B)
Buildings Sub Division, Vijayawada.

x counter signed

W. S. M. 13/9/21
Executive Engineer
(R&B) Division, Vijayawada.

13/9/2021